




PLUG NOT SUPPLIED

AIRIUS CEILING KIT MOUNTING GUIDELINES - Model 10, 15, 25, (Option 1)



P.O. Box 1812, Byron Bay, NSW 2481 E: info@airius.com.au W: www.airius.com.au

Office: +61 (0) 401 84 8888

AIRIUS<sup>®</sup>, AIR PEAR<sup>®</sup>, and THE THERMAL EQUALIZER<sup>®</sup> are trademarks of Airius, LLC, registered in the U.S. and in some countries abroad. Other trademarks pending in the U.S. and abroad.





AIRIUS CEILING KIT MOUNTING GUIDELINES - Model 10, 15, 25, (Option 2)

## (<u>.</u>) **Unistrut or Ceiling Beam** Cord Secured (...) Chains should be rated @ 39 Kgs each **Receptacle Rated** (Not supplied). 240 VAC Chains can be attached using carabiner, 240 v Plug hooks or bolts. (single phase) 0 300 VAC Rated Cord Furnished 1.2m Min void **OPTIONAL BY OTHERS:** Spigot to be sealed with flexible 280mm sealant & attached with screws. Hole to be cut by others. OR Minimum diameter 250mm. Spigot can also be attached to the **Airius Destratification Fan** side of the dome, but the duct must be supported near the If no side spigot attachment point and separately from the dome. access, min void 400mm Suspended ceiling For **Cooling** the Airius Air Pear fan should be located to suit client's requirements. Suggested locations are from just under the ceiling or closer to the floor to ensure suitable air cooling flow. For Heating or Conditioned Spaces the Airius Air Pear should be **Airius Ceiling Kit** securely installed as close as possible to the ceiling. The Airius discharge air column should have an unobstructed Intake Intake passage to the floor. The Airius unit should not be mounted Exhaust directly in front of heat ducts, vents or any other high heat source. **NOTE:** Remove hanging bail/handle from Air Pear The units must not be located closer than 3 metres to return air unit before installing into ceiling kit. ducts in conditioned spaces.

P.O. Box 1812, Byron Bay, NSW 2481 E: info@airius.com.au W: www.airius.com.au

Office: +61 (0) 401 84 8888

AIRIUS<sup>®</sup>, AIR PEAR<sup>®</sup>, and THE THERMAL EQUALIZER<sup>®</sup> are trademarks of Airius, LLC, registered in the U.S. and in some countries abroad. Other trademarks pending in the U.S. and abroad.

**PLUG NOT SUPPLIED**