

BMS CONTROL WIRING

EC Models Only

GENERAL NOTES

- 0-10 V signal allows infinitely variable open loop speed control
- Connecting the red and yellow leads will allow EC fans to operate at full speed
- A single controller can be used to control multiple fans with the same speed setting
- The BMS generates this voltage to send to the signal (yellow)
- Yellow is labeled as 0-10VDC because that is the acceptable range of voltages that the fan will accept

